

GENERAL NOTES:

- 1. PROVIDE SHOP DRAWINGS OF STRUCTURES.
- 2. PRECAST CONCRETE MANHOLES SHALL CONFORM TO ASTM C478, SHALL BE TYPE II ACID RESISTANT CEMENT AND SHALL MAINTAIN A MINIMUM COMPRESSIVE STRENGTH OF 4000 PSI IN 28 DAYS.
- 3. REFER TO FDOT INDEX 200 FOR ADDITIONAL DETAILS AND SPECIFICATIONS.
- 4. ALL REINFORCING BARS SHALL BE ASTM A615 GRADE 60, ALL COVER SHALL BE 3 INCHES MINIMUM.
- 5. ALL OPENINGS SHALL BE SEALED WITH ELASTOMETIC GROUT (TYPE 3 CEMENT).
- 6. O.D. = OUTSIDE DIAMETER.

CONFLICT MANHOLE N.T.S.

F:\WORK\\$ALL\CAD-DWG\STANDARDS\CMB STANDARD DETAILS\Public Works Manual\CMB Drainage Details



APPROVED

REVISED 05/31/2007 12/16/2009

STORM WATER DETAILS NO. 2 **CONFLICT MANHOLE**

SD15